

Memo No:- 3337

Date:- 16/10/2023

Subject : **Physical / Chemical Examination Report of Water Sample**


Sample ID/Classification : KNL/04336/10/2023 / Private	Sample Details	Date & Time
Sender : PRINCIPAL, VIVEKANAND SR.SEC.SCH25901	Collected By	
Location : , ADARSH NAGAR, KUNJPURA ROAD KARNAL	Collection Date	13/10/2023 at 14:46
Sample Description : Drinking Water	Received at lab	13/10/2023 at 14:55
Latitude / Longitude : 76.978080 / 29.688797	Analysis Start Date	13/10/2023
	Analysis End Date	14/10/2023
	Sample Quantity	1000ml

Test Result (As Per BIS 10500 :2012)

S.No.	Tested Parameter	Result	Requirement (Acceptable Limit)	Permissible Limit (In the Absence of Alternate Source)	Protocol Used
1	Total Dissolved Solids @ 180°C ± 2°C	350	500 mg/l.	2000 mg/l.	IS 3025 (Part-16) : 1984 (RA 2017)
2	Total Hardness as CaCO ₃	250	200 mg/l.	600 mg/l.	IS 3025 (Part-21) : 2009 (RA 2019)
3	Calcium as Ca	40	75 mg/l.	200 mg/l.	IS 3025 (Part-40) : 1991 (RA 2019)
4	Magnesium as Mg	36	30 mg/l.	100 mg/l.	IS 3025 (Part-46) : 1994 (RA 2019)
5	Iron as Fe	0.01	1.0 mg/l.	1.0 mg/l.	USEPA-8008:2017
6	Chloride as Cl	55	250 mg/l.	1000 mg/l.	IS 3025 (Part-32) : 1988 (RA 2019)
7	Sulphate as So ₄	20	200 mg/l.	400 mg/l.	USEPA-8051:2017
8	Fluoride as F	0.490	1.0 mg/l.	1.5 mg/l.	APHA 4500-F--C
9	Nitrate as No ₃	2.1	45 mg/l.	45 mg/l.	APHA 4500-NO ₃ - D
10	pH @ 25°C	7.51	6.5 - 8.5	6.5 - 8.5	IS 3025 (Part-11) : 1983 (RA 2017)
11	Total Alkalinity	270	200 mg/l.	600 mg/l.	IS 3025 (Part-23) : 1986 (RA 2019)
12	Color	<5	5 Hazen Units	15 Hazen Units	IS 3025 (Part-4) : 1983 (RA 2017)
13	Odour	Agreeable	Agreeable	Agreeable	IS 3025 (Part-5) : 1984 (RA 2018)
14	Taste	Agreeable	Agreeable	Agreeable	IS 3025 (Part-8) : 1984 (RA 2017)
15	Turbidity	<1	1 NTU	5 NTU	IS 3025 (Part-10):1984 (RA 2017)

Remarks :-

- * The Results Given above are related to the sample as received and tested in PHED KARNAL Lab.
- * The test report can't be regenerated in whole or part there of without written permission of Competent Authority.
- * The test report can't be used for any publicity or any legal purpose.
- * Reliability of water sample sample lies with sender/collector of water sample.
- * To check the sample report online Scan the QR Code below.
- * The test samples meant for chemical analysis will be disposed off after 15 days from the date of issue of test report unless until specifically requested by the customer for retaining over a longer period.



-----END OF TEST REPORT-----



**OFFICE OF CIVIL SURGEON
KARNAL-132001**



Ph. No. 0184-2267796, 2267569 Email: dhs.esknk@hry.nic.in

NO OBJECTION CERTIFICATE

Certify that the premises of Vivekanand Sr. Jec School
Adarsh Nagar Kunjura Road Karnal has been
inspected. The campus of the institute has been found satisfactory from
Sanitation & Hygienic point of view. This certificate is valid for one
year from the date of issue.

-Sd-
Dy. Civil Surgeon (Health)
Karnal

No. GH/SSI/2023/303

Date:- 28/0/23

A copy is forwarded to for information and necessary
action.

Principal Vivekanand Sr. Jec School Kunjura
Road Karnal.


Dy. Civil Surgeon (Health)
Karnal
Health (Karnal)

